



नवी मुंबई  
महानगरपालिका

Navi Mumbai  
Municipal Corporation

पर्यावरण प्रयोगशाळा  
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.  
दुरध्वनी क्र. : 2757 9882

JAS-ANZ



NMMC/Environment Laboratory/132/2024-2025  
Date : 16/01/2025

Date of sample received. : 16/01/2025 Date of sample testing : 16/01/2025 to 20/01/2025

Customer's Name and Location : Datta Meghe World Academy  
Sector - 16, Airoli  
Navi Mumbai 400 708

**TEST REPORT**


Sr. No.	Testing Parameter	Test Result	Test Standards ( IS 10500 : 2012 )
01	pH	7.5	6.5 - 8.5
02	Turbidity	1.8	Max. 5.0 N.T.U.
03	Residual Chlorine	0.1	Min. 0.2 mg/l
04	Bacteriological Test		
	Total Coliforms	0	0 per 100 ml
	E. Coli	- ve	- ve
	F. Coli	- ve	- ve

Test Report No. : 132

Date : 20/01/2025

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.

Lab Incharge

  
Lab Chemist

  
Environment Laboratory  
Navi Mumbai Municipal Corporation



Principal  
Datta Meghe World Academy  
CIDCO, Sector- 16, Airoli,  
Navi Mumbai- 400708.